

Khristie Davis, Purchasing Manager
khristiedavis@montgomerycountyal.gov
(334) 832-1267

Cynthia Hill, Buyer II
cynthiahill@montgomerycountyal.gov
(334) 832-2526

Jackie Weatherington, Buyer I
jackieweatherington@montgomerycountyal.gov
(334) 832-1603



PURCHASING DEPARTMENT

P.O. BOX 1667 MONTGOMERY, ALABAMA 36102-1667

Addendum to Bid No. 51100-25B-013

Addendum No. 1

June 18, 2025

This addendum is issued to make additions to the Scope of Services of original **Bid No. 51100-25B-013 Replacement of Rooftop HVAC Units**. The information in this addendum modifies and changes the original bidding document and takes precedence over the original document. Receipt of this addendum shall be acknowledged by the bidder signature and date below. Failure to acknowledge and submit this addendum with the bid may disqualify the bid.

Additions to the Scope of Services 2.03 – Contractors Responsibilities

- The Contractor must provide, install and startup a Distech EC BOS 9 JACE
- The factory start-up by equipment manufacturer is required for each HVAC Replacement Unit.

All other specifications shall remain the same.

Please sign and date below and attach to the front of bid forms when submitting them to the Purchasing Office to acknowledge receipt.

Name

Company

Signature

Date

Purchasing Agent/County Administrator